

CERTIFICATE OF COMPLIANCE

Certificate Number R40656
Report Reference R40656-20220803
Date 2022-August-03

Issued to: NUPI Americas, Inc.
314 COMMERCE PKWY
EARLY BRANCH SC, 29916 US

**This is to certify that
representative samples of**

INSULATED PLASTIC PIPE ASSEMBLIES CERTIFIED
FOR CANADA

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

CAN/ULC-S102.2:2018-REV1, Standard Method of Test for
Surface Burning Characteristics of Flooring, Floor
Coverings, and Miscellaneous Materials and Assemblies

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number R40656
Report Reference R40656-20220803
Date 2022-August-03

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Insulated polypropylene plastic pipe designated as "Niron Clima (SDR7.3, SDR9, SDR11, and SDR17)" intended to be installed with UL Classified "Owens Corning SSL II with ASJ Max Fiberglass Pipe Insulation" with a "FHC 25/50".



Bruce Mahrenholz, Director North American Certification Program



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>