

**Certification Statement for
Nupi Americas Inc. Double Wall Sump Penetration Fitting**

Based on Section 2631(d) of Title 23 from the California Code of Regulations and after my careful review and analysis, I hereby certify that Nupi Americas Inc. Double Wall Sump Penetration Fitting meets the requirements and standards of construction and operation for a non-integral secondary containment. This non-integral secondary containment will satisfy the necessary requirements as of July 1, 2004 as stipulated in the State Water Resources Control Board Local Guidance (LG) letter 162-1, Part II(A)(iii) by acting as a single-walled transition pipe contained within a double-walled sump that has a double-walled product tight lid that is continuously monitored using vacuum, pressure, or interstitial liquid level measurements. This system will perform the above function as long as the fitting is installed, operated, and maintained according to manufacturer's instructions and in a manner that does not exceed the limitations described below.

Limitations:

The fitting must be installed using the prescribed steps in the manufacturer's SEBEF installation manual. To ensure proper Petrol Seal™ performance, the preparation of surfaces to be applied with the substrate must be clean and contamination-free for proper adhesion of the compound.


Signed by (California Professional Engineer)

0CC 11-06
Date

MAURICE E. YEE
Printed Name (California Professional Engineer)



Nupi Americas Inc.

Company Name


California Professional Engineer
Registration Number

1511 Superior Way

Mailing Address

Houston, TX 77039

City, State, Zip Code


Signed by (Nupi Americas Inc. Representative)

Date